

## 中茂圣源在线监测数据（9月1日-9月30日）

时间	二氧化硫.			氮氧化物.			烟尘			氧气 (%)	烟气温度 (°C)	废气排放量 (m3)
	实测浓度 (mg/M3)	折算浓度 (mg/M3)	排放量 (t)	实测浓度 (mg/M3)	折算浓度 (mg/M3)	排放量 (t)	实测浓度 (mg/M3)	折算浓度 (mg/M3)	排放量 (t)			
2018-09-01	11.1	11.3	0.0144	17.4	17.6	0.0225	0.772	0.782	0.001	6.17	55.1	1289716
2018-09-02	10.1	9.97	0.0132	18.1	18	0.0237	0.725	0.719	0.001	5.86	55.5	1302104
2018-09-03	9.98	10.1	0.0126	23.3	23.6	0.0294	0.756	0.764	0.0009	6.16	55.1	1253457
2018-09-04	8.68	8.94	0.0103	17.2	17.7	0.0206	0.699	0.719	0.0008	6.43	53.8	1188537
2018-09-05	8.3	8.73	0.0027	13.6	14.5	0.0044	0.676	0.729	0.0002	6.74	53.9	318968
2018-09-10	8.49	19.8	0.0084	91.5	217	0.0863	0.597	1.12	0.0007	11.3	44.9	1121831
2018-09-11	5.02	5.06	0.0071	11.5	11.8	0.017	0.817	0.834	0.0012	6.33	53.4	1477447
2018-09-12	5.15	4.97	0.0064	6.62	6.4	0.0081	0.972	0.944	0.0012	5.53	54.7	1250325
2018-09-13	3.98	3.82	0.0048	14.5	14.1	0.0176	1.03	0.99	0.0012	5.47	55.5	1199526
2018-09-14	3.47	3.39	0.0043	20	19.6	0.0243	1.02	1	0.0012	5.72	55.4	1212175
2018-09-15	3.57	3.6	0.0043	18.1	18.3	0.0219	0.962	0.969	0.0012	6.13	54.8	1190093
2018-09-16	5.63	5.63	0.0062	10.8	10.9	0.012	0.93	0.935	0.001	6.07	54.7	1103271
2018-09-17	8.67	8.39	0.0098	13	12.6	0.0158	0.914	0.896	0.001	5.67	54.7	1120277
2018-09-18	9.41	8.97	0.0103	15.2	14.8	0.0175	0.905	0.877	0.001	5.48	55.5	1119695
2018-09-19	8.48	8.28	0.0101	19.8	19.4	0.0237	0.913	0.894	0.0011	5.69	55.7	1194286
2018-09-20	8.59	8.64	0.0105	28.9	29.1	0.0354	0.89	0.901	0.0011	6.13	54.7	1228984
2018-09-21	9	9	0.0116	31	31.2	0.041	0.873	0.871	0.0007	6.06	35.7	1303480
2018-09-22	8.9	9.68	0.0114	24.7	26.7	0.033	1.09	1.23	0.0007	7.3	31	1266176
2018-09-23	7.67	8.64	0.0087	28.2	31.8	0.0317	0.983	1.11	0.0011	7.75	54.9	1130930
2018-09-24	8.19	9.21	0.0091	28.6	32.3	0.0317	0.955	1.08	0.0011	7.69	54.9	1111104
2018-09-25	9.13	10.3	0.0103	26.1	29.4	0.0294	0.978	1.1	0.0011	7.69	55.1	1127680

2018-09-26	10.6	11.8	0.0119	27.5	30.8	0.0306	1.01	1.13	0.0012	7.58	55.4	1117331
2018-09-27	11.8	12.9	0.0125	24.6	27	0.0263	1	1.1	0.001	7.36	55.5	1059274
2018-09-28	11.6	13.2	0.0132	3.39	3.86	0.0039	1.03	1.17	0.0012	7.82	54.7	1134040
2018-09-29	14.9	15.4	0.0164	6.29	6.36	0.0069	1.04	1.1	0.0012	6.8	53.7	1099457
2018-09-30	16.8	16.4	0.0189	11.7	11.4	0.0132	1.14	1.11	0.0013	5.61	52.6	1122349
平均值	8.74	9.47	0.01	21.2	26.8	0.0242	0.91	0.965	0.001	6.64	52.7	1155481
最大值	16.8	19.8	0.0189	91.5	217	0.0863	1.14	1.23	0.0013	11.3	55.7	1477447
最小值	3.47	3.39	0.0027	3.39	3.86	0.0039	0.597	0.719	0.0002	5.47	31	318968
累计值			0.259			0.628			0.0264			30042515

注：2018年9月10日02点30分点炉运行，6时发现脱硝送药剂出现故障导致Nox折算值超标，于14时19分Nox值恢复正常。